



LCIE

BV LCIE
CHINA
Number

N°1466AS05PEA14022

ATTESTATION of conformity with European Directives

Product: Moulded Case Circuit Breaker
Reference: RDX6-63/DC Series
Issued to: PEOPLE ELE.APPLIANCE GROUP CO.,LTD.
Address: PEOPLE INDUSTRY ZONE,LIUSHI,YUEQING,ZHEJIANG
Manufacturer: PEOPLE ELE.APPLIANCE GROUP CO.,LTD.
Technical characteristics: Ui: 1000V
Uimp: 4kV.
Ue:DC1000V(4P in series)
In: 6A;10A;16A;20A;25A;32A;40A
Ics=Icu: 6kA
Utilization category: A
Number of poles: 4P

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:


- Low voltage directive 2006/95/EC

Standards	Report number	Report date
EN 60947-2:2006+A1:2009 ; EN 60947-1:2007+A1:2011	NF13-017	March 4th, 2014

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), May 28th, 2014



Holger SCHAFFER
Certification Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
上海欧亚电气技术咨询服务有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing
Songjiang High-Tech Park, Shanghai P.R.C
(201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com

Version 1.3/2012.11.21